

Automatic Tank Gauging (ATG) Page 5b

AUTOMATIC TANK GAUGING may be used as a method of leak detection for tanks if the ATG device and method has been third party tested and passed EPA protocol. The National Work Group on Leak Detection Evaluations lists leak detection devices that have been third party tested.

Facility Name	Facility ID#
---------------	--------------

Make of ATG (Required):	Model of ATG (Required):
-------------------------	--------------------------

UST Information: If a question does not apply, leave it blank.	MT TANK #	MT TANK #	MT TANK #	MT TANK #	MT TANK #
---	-----------	-----------	-----------	-----------	-----------

1	Is the ATG used as the primary method of tank leak detection?	YES NO	YES NO	YES NO	YES NO	YES NO
---	---	--------	--------	--------	--------	--------

2	Is the console box operational (turned on, equipped with roll of paper)?	YES NO	YES NO	YES NO	YES NO	YES NO
---	--	--------	--------	--------	--------	--------

3	Are monthly 0.2 gph leak tests conducted?	YES NO	YES NO	YES NO	YES NO	YES NO
---	---	--------	--------	--------	--------	--------

4	Are passing leak detection records available for the past twelve months?	YES NO	YES NO	YES NO	YES NO	YES NO
---	--	--------	--------	--------	--------	--------

5	<p>If question # 4 is marked “NO,” circle the months in which passing 0.2 gph leak test are NOT available.</p> <p>1 = January</p>	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3
		4	5	6	4	5	6	4	5	6	4	5	6	4	5	6
		7	8	9	7	8	9	7	8	9	7	8	9	7	8	9
		10	11	12	10	11	12	10	11	12	10	11	12	10	11	12

[illegible]

--	--	--	--

(Inspector Initial) (Date) (Owner/Operator Initial) (Date)